

	DEVICE					PROCESS/SYSTEM		CALIBRATION		CRITICALITY
ITEM	ASSET	TAG	DESCRIPTION / MANUFACTURER / SERIAL No.	RANGE	ACCURACY	RANGE	ACCURACY	RANGE	FREQUENCY	
1	HPSN0228	YE07 004	Temperature & Humidity Sensor Supplier 1 Serial number 1	-20 TO +80°C 0 TO 100%RH	± 0.5°C ± 2% RH	15 to 25°C 40 - 100 %RH	±2°C ± 10%RH	10 / 20 / 30 °C 30 TO 100 %RH	6 MONTHS	PRODUCT CRITICAL
2	HPSN0229	YE07 005	Temperature Sensor Supplier 2 Serial number 2	0 TO 60°C	± 0.5°C	15 to 25°C	±4°C	10 / 20 / 30 °C 11.4 / 54.1 / 74.7 %RH	6 MONTHS	PRODUCT CRITICAL
3	HPME0249	FE07 001	Static Air Pressure Transmitter Supplier 3 Serial number 3	0 TO 250 Pa	± 2 Pa	60 TO 200 Pa	± 15 Pa	50 TO 250 Pa	6 MONTHS	PRODUCT CRITICAL
4	HPME0250	FE07 002	Bag Filter Supplier 4 Serial number 4	0 TO 500 Pa	± 2 Pa	100 TO 400 Pa	± 20 Pa	50 TO 450 Pa	1 YEAR	PROCESS CRITICAL
5	HPME0251	FE07 003	Pre-Filter Supplier 5 Serial number 5	0 TO 250 Pa	± 5 Pa	0 TO 250 Pa	± 20 Pa	0 TO 250 Pa	1 YEAR	PROCESS CRITICAL
6	HPME0252	FE07 004	Bag Filter Supplier 6 Serial number 6	0 TO 500 Pa	± 10 Pa	0 TO 500 Pa	± 50 Pa	0 TO 500°C	1 YEAR	NON CRITICAL
7	HPSN0230	YT07 001	Duct Temperature Sensor Supplier 7 Serial number 7	-30 TO +35°C	± 0.5°C	-5 to +35°C	n/a	12°C	1 YEAR	NON CRITICAL